




AUTO-LATCH RESTRICTOR Mk2



Test Information


Tested by the BSI to BS6375:Part2:1987

Test Sample.

The restrictor was fitted to a PVCu window side hung window measuring 450 mm wide x 595 mm high double-glazed with a 4-20-4 sealed unit.

Summary of results.

The sample window when fitted with the restrictor met the requirements of the specification.



Strength test results

A7 test 6: Strength to restrict opening.

Force applied 200N for 5 seconds (maximum opening stops)
Window remained operable after force removed.

A7: Resistance to accidental loadings

Force applied 500N for 5 seconds.
No visible damage to the window was observed.
Force applied 1000N for 1 minute.
No distortion occurred. There was no glass breakage and the hardware remained attached to the sash and frame of the window.